

Q&A
4/7/2025

Request for Quotes (RFQ) For: Telecommunications Walk-In Cabinet equipment facility related to Okanogan County Electric Cooperative (OCEC) “Okanogan County Connect” project for Methow Fiber as funded by the Washington State Broadband Office (WSBO) Grant. Quotes shall be received by April 9, 2025, 5:00pm (PST)

Email bids to: aglenn@ocec.coop and jhardy@ocec.coop

Question:

1. It say’s “installation will be done by other”. However, it looks like the RFQ requires installation onto the PAD. Just want to confirm 100% that the RFQ requires the cabinet to be installed.
 - **INCLUDE THE ENTIRE INSTALLATION OF THE WIC TO THE PAD AND INSTALLING THE INTERNAL COMPONENTS TO A FULLY FUNCTIONAL STATE.**
 - **INCLUDE PROVIDING A COMPLET FOUNDATION DESIGN.**
 - **HIRE A LOCAL CONTRACTOR TO INSTALL THE FOUNDATION**
 - **HIRE A LOCAL ELECTRICAL CONTRACTOR TO INSTALL NEW ELECTRICAL SERVICE. Rich Milsteadt Electric (206) 618-6014 is familiar with the project. Propose a new service from overhead to underground. Utility Pole located 50’ +/-.**
 - **WIC TO BE INSTALLED AT 93 W CHEWUCH RD, WINTHROP WA**

